



**OPTIONAL ANNUAL REPORT TEMPLATE**

<b>Drinking-Water System Number:</b>	220000031
<b>Drinking-Water System Name:</b>	Clifford Drinking Water System
<b>Drinking-Water System Owner:</b>	Town of Minto
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2010 to December 31, 2010

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p><b>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ <input checked="" type="checkbox"/> ]</b></p> <p><b>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ <input checked="" type="checkbox"/> ] No [ ]</b></p> <p><b>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</b></p> <div style="border: 1px solid black; padding: 5px;"> <p>Town of Minto 5941 Hwy #89 R.R. #1 Harriston, ON N0G 1Z0</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p><b>Number of Designated Facilities served:</b></p> <div style="border: 1px solid black; width: 100px; text-align: center; margin: 5px;">N/A</div> <p><b>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</b></p> <p><b>Number of Interested Authorities you report to:</b></p> <div style="border: 1px solid black; width: 100px; text-align: center; margin: 5px;">N/A</div> <p><b>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</b></p>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

**List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
N/A	N/A



**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?**

Yes [] No []

**Indicate how you notified system users that your annual report is available, and is free of charge.**

- [  ] **Public access/notice via the web**      Town of Minto Website  
[  ] **Public access/notice via Government Office**  
[  ] **Public access/notice via a newspaper**      Advertisement put in Local Newspaper  
[  ] **Public access/notice via Public Request**  
[  ] **Public access/notice via a Public Library**  
[  ] **Public access/notice via other method**      Tax Letter

**Describe your Drinking-Water System**

Clifford is currently serviced by a municipal water system that consists of: three drilled bedrock wells, two pumphouses; a 1275 m<sup>3</sup> elevated storage facility and a distribution network. In the event of a prolonged power outage, a portable generator is available to Well #1 to supply back-up power.

The bedrock wells are equipped with submersible pumps that discharge directly into the respective pumphouse. In the pumphouse, the raw water supply is injected with 12% sodium hypochlorite for disinfection and the chemical sodium silicate, for iron sequestering. The treated water from Well #1 leaves the pumphouse and enters an underground contact pipe and is discharged into the distribution system after adequate contact time is achieved. Treated water from Well #3 and #4 is discharged back into the elevated storage tank before being discharged into the distribution system.

The wells are controlled (start/stop) automatically based on elevated storage tank liquid levels and pressures in the distribution system. Each pumphouse is equipped with alarms for chlorination system failure (and corresponding lockout of well pumps), low water level and intrusion. Each wellhouse has a continuous monitoring analyzer for chlorine with lockouts and alarms.

**List all water treatment chemicals used over this reporting period**

- 12% Sodium Hypochlorite (disinfectant)
- Sodium Silicate (sequestering agent)



**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

To meet the requirements of O. Reg. 170/03, upgrades, installation and replacement of various system components have been completed. However, maintaining the system includes repair and replacement of individual components as required.

In 2010, approximately \$230.00 was spent on equipment and \$90,000.00 was spent installing watermain.

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A	N/A	N/A	N/A	N/A	N/A

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

Type / Location of Sample		Number of Samples	Range of E. Coli or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Range of HPC (min #)-(max #)	Number of HPC or BKG Samples
<b>Raw</b>	Well #1	52	0 - 0	0 - 0	N/A	N/A
	Well #3	52	0 - 0	0 - 0	N/A	N/A
	Well #4	52	0 - 0	0 - 0	N/A	N/A
<b>Treated</b>	Well #1	52	0 - 0	0 - 0	< 10 – 130	52
	Well #3	52	0 - 0	0 - 0	< 10 – 20	52
	Well #4	52	0 - 0	0 - 0	< 10 – 130	52
<b>Distribution</b>		156	0 – 0	0 - 0	< 10 - > 2000	156

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

Operational Testing		Number of Grab Samples	Range of Results (min #) – (max #)	
<b>Turbidity</b>	<b>Raw</b>	Well #1	133	0.05 – 0.79
		Well #3	122	0.01 – 0.87
		Well #4	96	0.01 – 0.91
<b>Chlorine</b>	<b>Treated</b>	Well #1	362	0.32 – 1.72
		Well #3	358	0.79 – 1.74
		Well #4	306	0.00 – 1.80
	<b>Distribution</b>	546	0.29 – 1.59	
<b>Fluoride</b> (If the DWS provides fluoridation)		N/A	N/A	

**NOTE:** Record the unit of measure if it is **not** milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A	N/A	N/A	N/A	N/A

### Clifford Well #1

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	19/05/10	<0.6	(ug/L)	6
<b>Arsenic</b>	19/05/10	5.2	(ug/L)	25
<b>Barium</b>	19/05/10	149	(ug/L)	1000
<b>Boron</b>	19/05/10	<50	(ug/L)	5000
<b>Cadmium</b>	19/05/10	<0.1	(ug/L)	5
<b>Chromium</b>	19/05/10	<1.0	(ug/L)	50
<b>*Lead</b>			(ug/L)	10

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Mercury	19/05/10	<0.1	(ug/L)	1
Selenium	19/05/10	<5.0	(ug/L)	10
Sodium	19/06/07	12.9	(mg/L)	20
Uranium	19/05/10	<5.0	(ug/L)	20
Fluoride	19/06/07	0.8	(mg/L)	1.5
Nitrite	08/02/10	<0.1	(mg/L)	1
	19/05/10	<0.1		
	16/08/10	<0.1		
	08/11/10	<0.1		
Nitrate	08/02/10	<0.1	(mg/L)	10
	19/05/10	<0.1		
	16/08/10	0.21		
	08/11/10	<0.1		

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

### **Clifford Well #3**

#### **Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	19/05/10	<0.6	(ug/L)	6
Arsenic	19/05/10	<1.0	(ug/L)	25
Barium	19/05/10	107	(ug/L)	1000
Boron	19/05/10	<50	(ug/L)	5000
Cadmium	19/05/10	<0.1	(ug/L)	5
Chromium	19/05/10	<1.0	(ug/L)	50
*Lead			(ug/L)	100
Mercury	19/05/10	<0.1	(ug/L)	1
Selenium	19/05/10	<5.0	(ug/L)	10
Sodium	19/06/07	13	(mg/L)	20
Uranium	19/05/10	<5.0	(ug/L)	20
Fluoride	19/06/07	0.2	(mg/L)	1.5
Nitrite	08/02/10	<0.1	(mg/L)	1
	19/05/10	<0.1		
	16/08/10	<0.1		
	08/11/10	<0.1		



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Nitrate	08/02/10	0.22	(mg/L)	10
	19/05/10	0.19		
	16/08/10	<0.1	(mg/L)	10
	08/11/10	0.25		

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Clifford Well #4**

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	19/05/10	<0.6	(ug/L)	6
Arsenic	19/05/10	7.3	(ug/L)	25
Barium	19/05/10	121	(ug/L)	1000
Boron	19/05/10	<50	(ug/L)	5000
Cadmium	19/05/10	<0.1	(ug/L)	5
Chromium	19/05/10	<1.0	(ug/L)	50
*Lead			(ug/L)	100
Mercury	19/05/10	<0.1	(ug/L)	1
Selenium	19/05/10	<5.0	(ug/L)	10
Sodium	19/06/07	9.6	(mg/L)	20
Uranium	19/05/10	<5.0	(ug/L)	20
Fluoride	19/06/07	0.2	(mg/L)	1.5
Nitrite	08/02/10	<0.1	(mg/L)	1
	19/05/10	<0.1		
	16/08/10	<0.1		
	08/11/10	<0.1		
Nitrate	08/02/10	<0.1	(mg/L)	10
	19/05/10	<0.1		
	16/08/10	<0.1		
	08/11/10	<0.1		

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	81	<1 – 3 ug/L	N/A
Distribution	8	<1 – <1 ug/L	N/A

\* These results are from samples taken in January and August 2008.  
 No adverse results were identified.  
 Further Testing is not required until January 2011.

**Clifford Well #1**

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	19/05/10	<0.1	(ug/L)	5
Aldicarb	19/05/10	<1	(ug/L)	9
Aldrin	19/05/10	<0.02	(ug/L)	
Aldrin + Dieldrin	19/05/10	<0.04	(ug/L)	0.7
alpha-Chlordane	19/05/10	<0.1	(ug/L)	
Aroclor 1242	19/05/10	<0.02	(ug/L)	
Aroclor 1254	19/05/10	<0.02	(ug/L)	
Aroclor 1260	19/05/10	<0.02	(ug/L)	
Atrazine	19/05/10	<0.2	(ug/L)	
Atrazine Desethyl	19/05/10	<0.1	(ug/L)	
Atrazine & Metabolites	19/05/10	<0.2	(ug/L)	5
Azinphos-methyl	19/05/10	<0.1	(ug/L)	20
Bendiocarb	19/05/10	<0.2	(ug/L)	40
Benzene	19/05/10	<0.5	(ug/L)	5
Benzo(a)pyrene	19/05/10	<0.01	(ug/L)	0.01
Bromoxynil	19/05/10	<0.2	(ug/L)	5
Carbaryl	19/05/10	<0.2	(ug/L)	90
Carbofuran	19/05/10	<0.2	(ug/L)	90
Carbon Tetrachloride	19/05/10	<0.5	(ug/L)	5
Chlordane (Total)	19/05/10	<0.3	(ug/L)	7
Chlorpyrifos	19/05/10	<0.1	(ug/L)	90



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Cyanazine	19/05/10	<0.1	(ug/L)	10
Diazinon	19/05/10	<0.1	(ug/L)	20
Dicamba	19/05/10	<0.2	(ug/L)	120
1,2-Dichlorobenzene	19/05/10	<0.5	(ug/L)	200
1,4-Dichlorobenzene	19/05/10	<0.5	(ug/L)	5
Dichlorodiphenyltrichloroethane (DDT) + metabolites	19/05/10	<0.4	(ug/L)	30
1,2-Dichloroethane	19/05/10	<0.5	(ug/L)	5
1,1-Dichloroethylene (vinylidene chloride)	19/05/10	<0.5	(ug/L)	14
Dichloromethane	19/05/10	<0.5	(ug/L)	50
2-4 Dichlorophenol	19/05/10	<0.5	(ug/L)	900
2,4-Dichlorophenoxy acetic acid (2,4-D)	19/05/10	<0.2	(ug/L)	100
Diclofop-methyl	19/05/10	<0.2	(ug/L)	9
Dieldrin	19/05/10	<0.02	(ug/L)	
Dimethoate	19/05/10	<0.1	(ug/L)	20
Dinoseb	19/05/10	<0.2	(ug/L)	10
Diquat	19/05/10	<1	(ug/L)	70
Diuron	19/05/10	<1	(ug/L)	150
gamma-Chlordane	19/05/10	<0.1	(ug/L)	
Glyphosate	19/05/10	<5	(ug/L)	280
Heptachlor + Heptachlor Epoxide	19/05/10	<0.2	(ug/L)	3
Heptachlor	19/05/10	<0.1	(ug/L)	
Heptachlor Epoxide	19/05/10	<0.1	(ug/L)	
Lindane (Total)	19/05/10	<0.1	(ug/L)	4
Malathion	19/05/10	<0.1	(ug/L)	190
Methoxychlor	19/05/10	<0.1	(ug/L)	900
Metolachlor	19/05/10	<0.1	(ug/L)	50
Metribuzin	19/05/10	<0.1	(ug/L)	80
Monochlorobenzene	19/05/10	<0.5	(ug/L)	80
o,p-DDT	19/05/10	<0.1	(ug/L)	
Oxychlordane	19/05/10	<0.1	(ug/L)	
p,p-DDD	19/05/10	<0.1	(ug/L)	
p,p-DDE	19/05/10	<0.1	(ug/L)	
p,p-DDT	19/05/10	<0.1	(ug/L)	
Paraquat	19/05/10	<1.0	(ug/L)	10
Parathion	19/05/10	<0.1	(ug/L)	50
Pentachlorophenol	19/05/10	<0.5	(ug/L)	60
Phorate	19/05/10	<0.1	(ug/L)	2
Picloram	19/05/10	<0.2	(ug/L)	190
Polychlorinated Biphenyls (PCB)	19/05/10	<0.02	(ug/L)	3
Prometryne	19/05/10	<0.1	(ug/L)	1
Simazine	19/05/10	<0.1	(ug/L)	10





Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
THM	08/02/10	7.8	(ug/L)	100
	19/05/10	11.8	(ug/L)	100
	16/08/10	10.2		
	08/11/10	8.9		
Temephos	19/05/10	<0.1	(ug/L)	280
Terbufos	19/05/10	<0.2	(ug/L)	1
Tetrachloroethylene (perchloroethylene)	19/05/10	<0.5	(ug/L)	30
2,3,4,6-Tetrachlorophenol	19/05/10	<0.5	(ug/L)	100
Triallate	19/05/10	<0.1	(ug/L)	230
Trichloroethylene	19/05/10	<0.5	(ug/L)	5
2,4,6-Trichlorophenol	19/05/10	<0.5	(ug/L)	5
2,4,5-Trichlorophenoxy acetic acid (2,4,5,-T)	19/05/10	<0.2	(ug/L)	280
Trifluralin	19/05/10	<0.1	(ug/L)	45
Vinyl Chloride	19/05/10	<0.5	(ug/L)	2

**Clifford Well #3**

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	19/05/10	<0.1	(ug/L)	5
Aldicarb	19/05/10	<1.0	(ug/L)	9
Aldrin	19/05/10	<0.02	(ug/L)	
Aldrin + Dieldrin	19/05/10	<0.04	(ug/L)	0.7
alpha-Chlordane	19/05/10	<0.1	(ug/L)	
Aroclor 1242	19/05/10	<0.02	(ug/L)	
Aroclor 1254	19/05/10	<0.02	(ug/L)	
Aroclor 1260	19/05/10	<0.02	(ug/L)	
Atrazine	19/05/10	<0.1	(ug/L)	
Atrazine Desethyl	19/05/10	<0.1	(ug/L)	
Atrazine & Metabolites	19/05/10	<0.2	(ug/L)	5
Azinphos-methyl	19/05/10	<0.1	(ug/L)	20
Bendiocarb	19/05/10	<0.2	(ug/L)	40
Benzene	19/05/10	<0.5	(ug/L)	5
Benzo(a)pyrene	19/05/10	<0.01	(ug/L)	0.01
Bromoxynil	19/05/10	<0.2	(ug/L)	5
Carbaryl	19/05/10	<0.2	(ug/L)	90
Carbofuran	19/05/10	<0.2	(ug/L)	90
Carbon Tetrachloride	19/05/10	<0.5	(ug/L)	5



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Chlordane (Total)	19/05/10	<0.3	(ug/L)	7
Chlorpyrifos	19/05/10	<0.1	(ug/L)	90
Cyanazine	19/05/10	<0.1	(ug/L)	10
Diazinon	19/05/10	<0.1	(ug/L)	20
Dicamba	19/05/10	<0.2	(ug/L)	120
1,2-Dichlorobenzene	19/05/10	<0.5	(ug/L)	200
1,4-Dichlorobenzene	19/05/10	<0.5	(ug/L)	5
Dichlorodiphenyltrichloroethane (DDT) + metabolites	19/05/10	<0.4	(ug/L)	30
1,2-Dichloroethane	19/05/10	<0.5	(ug/L)	5
1,1-Dichloroethylene (vinylidene chloride)	19/05/10	<0.5	(ug/L)	14
Dichloromethane	19/05/10	<0.5	(ug/L)	50
2,4 Dichlorophenol	19/05/10	<0.5	(ug/L)	900
2,4-Dichlorophenoxy acetic acid (2,4-D)	19/05/10	<0.2	(ug/L)	100
Diclofop-methyl	19/05/10	<0.2	(ug/L)	9
Dieldrin	19/05/10	<0.02	(ug/L)	
Dimethoate	19/05/10	<0.1	(ug/L)	20
Dinoseb	19/05/10	<0.2	(ug/L)	10
Diquat	19/05/10	<1.0	(ug/L)	70
Diuron	19/05/10	<1.0	(ug/L)	150
gamma-Chlordane	19/05/10	<0.1	(ug/L)	
Glyphosate	19/05/10	<5.0	(ug/L)	280
Heptachlor + Heptachlor Epoxide	19/05/10	<0.2	(ug/L)	3
Heptachlor	19/05/10	<0.1	(ug/L)	
Heptachlor Epoxide	19/05/10	<0.1	(ug/L)	
Lindane (Total)	19/05/10	<0.1	(ug/L)	4
Malathion	19/05/10	<0.1	(ug/L)	190
Methoxychlor	19/05/10	<0.1	(ug/L)	900
Metolachlor	19/05/10	<0.1	(ug/L)	50
Metribuzin	19/05/10	<0.1	(ug/L)	80
Monochlorobenzene	19/05/10	<0.5	(ug/L)	80
o,p-DDT	19/05/10	<0.1	(ug/L)	
Oxychlordane	19/05/10	<0.1	(ug/L)	
p,p-DDD	19/05/10	<0.1	(ug/L)	
p,p-DDE	19/05/10	<0.1	(ug/L)	
p,p-DDT	19/05/10	<0.1	(ug/L)	
Paraquat	19/05/10	<1	(ug/L)	10
Parathion	19/05/10	<0.1	(ug/L)	50
Pentachlorophenol	19/05/10	<0.5	(ug/L)	60
Phorate	19/05/10	<0.1	(ug/L)	2
Picloram	19/05/10	<0.2	(ug/L)	190



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Polychlorinated Biphenyls (PCB)	19/05/10	<0.02	(ug/L)	3
Prometryne	19/05/10	<0.1	(ug/L)	1
Simazine	19/05/10	<0.1	(ug/L)	10
THM	08/02/10	7.8	(ug/L)	100
	19/05/10	11.8		
	16/08/10	10.2		
	08/11/10	8.9		
Temephos	19/05/10	<0.1	(ug/L)	280
Terbufos	19/05/10	<0.2	(ug/L)	1
Tetrachloroethylene (perchloroethylene)	19/05/10	<0.5	(ug/L)	30
2,3,4,6-Tetrachlorophenol	19/05/10	<0.5	(ug/L)	100
Triallate	19/05/10	<0.1	(ug/L)	230
Trichloroethylene	19/05/10	<0.5	(ug/L)	5
2,4,6-Trichlorophenol	19/05/10	<0.5	(ug/L)	5
2,4,5-Trichlorophenoxy acetic acid (2,4,5,-T)	19/05/10	<0.2	(ug/L)	280
Trifluralin	19/05/10	<0.1	(ug/L)	45
Vinyl Chloride	19/05/10	<0.5	(ug/L)	2

**Clifford Well #4**

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	19/05/10	<0.1	(ug/L)	5
Aldicarb	19/05/10	<1.0	(ug/L)	9
Aldrin	19/05/10	<0.02	(ug/L)	
Aldrin + Dieldrin	19/05/10	<0.04	(ug/L)	0.7
alpha-Chlordane	19/05/10	<0.1	(ug/L)	
Aroclor 1242	19/05/10	<0.02	(ug/L)	
Aroclor 1254	19/05/10	<0.02	(ug/L)	
Aroclor 1260	19/05/10	<0.02	(ug/L)	
Atrazine	19/05/10	<0.1	(ug/L)	
Atrazine Desethyl	19/05/10	<0.1	(ug/L)	
Atrazine & Metabolites	19/05/10	<0.2	(ug/L)	5
Azinphos-methyl	19/05/10	<0.1	(ug/L)	20
Bendiocarb	19/05/10	<0.2	(ug/L)	40
Benzene	19/05/10	<0.5	(ug/L)	5
Benzo(a)pyrene	19/05/10	<0.01	(ug/L)	0.01



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Bromoxynil	19/05/10	<0.2	(ug/L)	5
Carbaryl	19/05/10	<0.2	(ug/L)	90
Carbofuran	19/05/10	<0.2	(ug/L)	90
Carbon Tetrachloride	19/05/10	<0.5	(ug/L)	5
Chlordane (Total)	19/05/10	<0.3	(ug/L)	7
Chlorpyrifos	19/05/10	<0.1	(ug/L)	90
Cyanazine	19/05/10	<0.1	(ug/L)	10
Diazinon	19/05/10	<0.1	(ug/L)	20
Dicamba	19/05/10	<0.2	(ug/L)	120
1,2-Dichlorobenzene	19/05/10	<0.5	(ug/L)	200
1,4-Dichlorobenzene	19/05/10	<0.5	(ug/L)	5
Dichlorodiphenyltrichloroethane (DDT) + metabolites	19/05/10	<0.4	(ug/L)	30
1,2-Dichloroethane	19/05/10	<0.5	(ug/L)	5
1,1-Dichloroethylene (vinylidene chloride)	19/05/10	<0.5	(ug/L)	14
Dichloromethane	19/05/10	<0.5	(ug/L)	50
2,4 Dichlorophenol	19/05/10	<0.5	(ug/L)	900
2,4-Dichlorophenoxy acetic acid (2,4-D)	19/05/10	<0.2	(ug/L)	100
Diclofop-methyl	19/05/10	<0.2	(ug/L)	9
Dieldrin	19/05/10	<0.02	(ug/L)	
Dimethoate	19/05/10	<0.1	(ug/L)	20
Dinoseb	19/05/10	<0.2	(ug/L)	10
Diquat	19/05/10	<1.0	(ug/L)	70
Diuron	19/05/10	<1.0	(ug/L)	150
gamma-Chlordane	19/05/10	<0.1	(ug/L)	
Glyphosate	19/05/10	<5.0	(ug/L)	280
Heptachlor + Heptachlor Epoxide	19/05/10	<0.2	(ug/L)	3
Heptachlor	19/05/10	<0.1	(ug/L)	
Heptachlor Epoxide	19/05/10	<0.1	(ug/L)	
Lindane (Total)	19/05/10	<0.1	(ug/L)	4
Malathion	19/05/10	<0.1	(ug/L)	190
Methoxychlor	19/05/10	<0.1	(ug/L)	900
Metolachlor	19/05/10	<0.1	(ug/L)	50
Metribuzin	19/05/10	<0.1	(ug/L)	80
Monochlorobenzene	19/05/10	<0.5	(ug/L)	80
o,p-DDT	19/05/10	<0.1	(ug/L)	
Oxychlordane	19/05/10	<0.1	(ug/L)	
p,p-DDD	19/05/10	<0.1	(ug/L)	
p,p-DDE	19/05/10	<0.1	(ug/L)	
p,p-DDT	19/05/10	<0.1	(ug/L)	
Paraquat	19/05/10	<1	(ug/L)	10



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Parathion	19/05/10	<0.1	(ug/L)	50
Pentachlorophenol	19/05/10	<0.5	(ug/L)	60
Phorate	19/05/10	<0.1	(ug/L)	2
Picloram	19/05/10	<0.2	(ug/L)	190
Polychlorinated Biphenyls (PCB)	19/05/10	<0.02	(ug/L)	3
Prometryne	19/05/10	<0.1	(ug/L)	1
Simazine	19/05/10	<0.1	(ug/L)	10
THM	08/02/10	7.8	(ug/L)	100
	19/05/10	11.8		
	16/08/10	10.2		
	08/11/10	8.9		
Temephos	19/05/10	<0.1	(ug/L)	280
Terbufos	19/05/10	<0.2	(ug/L)	1
Tetrachloroethylene (perchloroethylene)	19/05/10	<0.5	(ug/L)	30
2,3,4,6-Tetrachlorophenol	19/05/10	<0.5	(ug/L)	100
Triallate	19/05/10	<0.1	(ug/L)	230
Trichloroethylene	19/05/10	<0.5	(ug/L)	5
2,4,6-Trichlorophenol	19/05/10	<0.5	(ug/L)	5
2,4,5-Trichlorophenoxy acetic acid (2,4,5,-T)	19/05/10	<0.2	(ug/L)	280
Trifluralin	19/05/10	<0.1	(ug/L)	45
Vinyl Chloride	19/05/10	<0.5	(ug/L)	2

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample
N/A	N/A	N/A	N/A

*(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)*