



DIETRICH ENGINEERING LIMITED
CONSULTING ENGINEERS

515 Dotzert Crt., Unit 8, Waterloo, ON, N2L 6A7 | T: (519) 880-2708 | F: (519) 880-2709 | E: mail@dietricheng.com

ADDENDUM 1

July 30, 2014

To Whom it May Concern

Re: Third Line Culvert Replacement - Tender
Town of Minto
Our Reference No. 1372

In connection with the above noted project, the following changes have been made to item 3) in the Scope of Work:

1. 5.48m span x 3.53m rise Multi-Plate Arched Pipe Culvert shall **not** have beveled ends.
2. The corrugations of the 5.48m span x 3.53m rise Multi-Plate Arched Pipe Culvert shall be 152mm x 51mm.

If you have any questions, please don't hesitate to contact the undersigned.

Yours truly,

DIETRICH ENGINEERING LIMITED

A handwritten signature in black ink, appearing to read 'MT'.

Michel Terzian

MT.